From:	Philip Mudd
To:	Danny Mapili - WPD-C
Cc:	tony.lopacki@gsa.gov; Lynn.Goldfarb@perkinswill.com; Ruschaupt, Chris @ Washington DC (Chris.Ruschaupt@cbre.com); Terry Lamb Sr.; Joshua Hill; Thomas.Gregory@perkinswill.com
Subject:	RE: FW: Water filter specifications
Date:	Thursday, April 07, 2016 11:40:21 AM

Yes

Thank you

From: Danny Mapili - WPD-C [mailto:danny.mapili@gsa.gov]
Sent: Thursday, April 07, 2016 11:00 AM
To: Philip Mudd
Cc: tony.lopacki@gsa.gov; Lynn.Goldfarb@perkinswill.com; Ruschaupt, Chris @ Washington DC (Chris.Ruschaupt@cbre.com); Terry Lamb Sr.; Joshua Hill; Thomas.Gregory@perkinswill.com
Subject: Re: FW: Water filter specifications

Philip,
There was a static on the line, and I did not hear Chris' and Tom's response. Are you satisfied with the response?

Let me know of any other issues.

Thanks,

Danny C. Mapili
Project Manager
Lease Projects Division
Office of Design and Construction
NCR-PBS
U.S. General Services Administration
P 202-219-0376 | M 703-678-8289

On Thu, Apr 7, 2016 at 7:29 AM, Philip Mudd <Philip.Mudd@ferc.gov> wrote:

Please make sure these details get added to the drawings. The CUNO brand that is aqua-pure's AP-11T has failed repeatedly, we changed to the EVERPURE E-Series housing. The "O" rings do not fail, they have a much more substantial construction and a sturdy mounting system. The 4 west galley has an example and I have sample of both the filter & the housing. Our building engineers prefer the EVERPURE E-Series housing

Phil

Federal Energy Regulatory Commission
888 First Street NE 41-72
Washington DC 20426
Philip.mudd@ferc.gov
202-502-646 desk

202-641-6001 cell